

TEST CERTIFICATE

Certificate Nr: EEA – 1600 – 0042

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratory** on 09.12.2016 in accordance with EN 81-58:2003 standard for the product as described below:

“ VCK ” INSULATED LIFT LANDING DOOR

Two Panels Central Opening

FIRE RESISTANCE CLASSIFICATION

E 30, EI 30

Placed on the market by

VİTAL ASANSÖR ELEKTRİK ELEKTRONİK MAK. SAN. TİC. LTD. ŞTİ.
Fevzi Çakmak Mah. Büsan 4. Özel Org. San. Şif. Aslım Cad. No:35 Karatay, KONYA, TURKEY
And Produced In the Factory

VİTAL ASANSÖR ELEKTRİK ELEKTRONİK MAK. SAN. TİC. LTD. ŞTİ.
Fevzi Çakmak Mah. Büsan 4. Özel Org. San. Şif. Aslım Cad. No:35 Karatay, KONYA, TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **RFTR16204**.



Ali BAYRAKTAR
Laboratory Manager

